

May 6, 2016

Mr. Lucas Schwaiger  
 HILTI, Inc.  
 3701 W Royal Lane, Suite 100  
 Irvine, TX 75063

Subject: VOC/EPA Method 24 Testing of Hilti Firestop Composite Sheet  
 LEGEND No: 1601700

**1.0 INTRODUCTION**

LEGEND TECHNICAL SERVICES, INC. (LEGEND) received one sample from a representative of Hilti Corporation on April 11, 2016. LEGEND's scope of work was limited to the analysis of the volatile organic compounds (VOC) per EPA Method 24.

**2.0 SAMPLE IDENTIFICATION**

Laboratory Identification	Client Identification
1601700-01	Firestop Composite Sheet

**3.0 METHODOLOGY**

The VOC content was determined per EPA Method 24.

**4.0 RESULTS**

The results are summarized below.

Test Parameter	Firestop Composite Sheet (1601700-01)
VOC % (less exempt compounds)	0.096
VOC gram/Liter (corrected for density)	1.0

**5.0 REMARKS**

The unconsumed sample will be retained by our laboratory for 30 days from the date of this report and then discarded unless further instructions are received from the client.

Submitted by:  
 LEGEND TECHNICAL SERVICES, INC.

Tom Barrett  
 Vice President  
 Strategic Analytical Services